

Snow GUARDS 07 72 53
VentSaver Vent Pipe Protector Specification Sheet:
VentSaver FB 151, VentSaver P 383 and VentSaver HD (Heavy Duty)

3 Part Specification Sheet

Part 1: General

1.01 SUMMARY

A. Work Includes

1. VentSaver aluminum snow diverter that attaches directly to the roof deck and straps to vent pipes/exhaust vents.
2. Determine proper method of attachment.

B. Related Sections

1. Master Format™ 2004 Section 23 35 19 – Industrial Ventilation and Exhaust
2. Master Format™ 2004 Section 23 73 33 – Heating/Ventilation/Air Conditioning System
3. Division 15: Mechanical
4. Master Format™ 2004 Section 07 61 13 – Air Supply, Distribution, Ventilation, and Exhaust System
5. Master Format™ 2004 Section 07 60 00 – Flashing and Sheet Metal
6. Master Format™ 2004 Section 07 72 00 – Roof Accessories.
7. Division 7: Thermal and Moisture Protection

1.02 SYSTEM DESCRIPTION

A. Components

1. VentSaver system that consists of individual aluminum snow diverter kit to protect a roof stack, chimney or mast.
2. Fasteners
 - a. Non Floating Mechanically Fastened Metal Roofs: Attach with (4) 1-1/2" lag screws, strapping, all weather sealant.

1.03 SUBMITTALS

A. For Review

1. Cut sheets with descriptions of product(s) and installation instructions.

1.04 QUALITY ASSURANCE

- A. Installer shall have at least 5 years experience installing the specified roofing material and accessories.**

1.05 WARRANTY

A. Lifetime Warranty

1. Provide warranty information from manufacturer covering against material and/or workmanship defect(s).

Part 2: Product

2.01 ACCEPTABLE MANUFACTURER

IceBlox, Inc., d.b.a.

Snoblox-Snojax
1405 Brandon Road
Mechanicsburg, PA 17055

Phone:
(800) 766-5291
(717) 737-4398

Fax:
(800) 634-7906
(717) 697-6141

Online:
www.ventsaver.com
support@snojax.com

Warehouse:
671 Willow Street
Lemoyne, PA 17043

2.02 MATERIALS

A. Materials

1. Non-corrosive powder coated aircraft grade aluminum
2. Pre-punched stainless steel strap or cable
3. Stainless steel nuts, bolts, and heavy duty 1-1/2" lag screws

2.03 FINISH

- A. Powder coated grey or black depending on model.**

Part 3 Execution

3.01 EXAMINATION

A. Substrate

1. Validate that the roofing material has been installed correctly and structure is adequate prior to installing snow guards.
1. Confirm the substrate below is at least a 2" thick and that the provided 1-1/2" lag screws engage fully.

3.02 INSTALLATION

- A. Comply with architectural guidelines and follow manufacturer's written installation instructions for installation**